



LEGEND:

- 1 FACILITIES OFFICE BUILDING, METER # 112641  
- WASHROOMS  
- HEAT / AC  
- POWER, TELEPHONE  
- 2 OFFICE SPACES  
- GENERAL MEETING SPACE
- 2 ELECTRICAL BUILDING, METER # 177369  
- 1200 AMP 120/208 VOLT, 3 PHASE MAIN SERVICE  
- 1200 AMP 120/208 VOLT, 3 PHASE MANUAL TRANSFER SWITCH  
- GENERATOR (BY OTHERS)
- 3 MAIN TRANSFORMER
- 4 PDU #1 - FRONT OF HOUSE  
- IN GROUND CONNECTION POINT FOR 100 AMP, 120/208 VOLT, 3 PHASE SERVICE  
- 1 EMPTY CONDUIT  
- DISTRIBUTION PANEL (BY OTHERS)
- 5 PDU #2& #4 - PORTABLE STAGE AREA  
- IN GROUND CONNECTION POINT FOR 400 AMP, 120/208 VOLT, 3 PHASE SERVICE & 200 AMP 120/208 VOLT, 3 PHASE SERVICE  
- DISTRIBUTION PANEL (BY OTHERS)
- 6 PDU #3 - PORTABLE STAGE AREA  
- IN GROUND CONNECTION POINT FOR 400 AMP, 120/208 VOLT, 3 PHASE SERVICE
- 7 PDU #2a & 3a - PORTABLE STAGE AREA  
- 2 - 4" DIA UNDERGROUND CONDUITS TO PDU #3
- 8 T4 POWER PANEL  
- 75 KVA OF 600 VOLT, 3 PHASE SERVICE INCLUSIVE 45 KVA OF 120/208, 3 PHASE SERVICE  
- WITH 24 CIRCUIT POWER PANEL
- 9 T5 POWER PANEL  
- 112 KVA OF 600 VOLT, 3 PHASE SERVICE INCLUSIVE 45 KVA OF 120/208, 3 PHASE SERVICE  
- WITH 24 CIRCUIT POWER PANEL
- 10 T6 POWER PANEL  
- 75 KVA OF 600 VOLT, 3 PHASE SERVICE INCLUSIVE 45 KVA OF 120/208, 3 PHASE SERVICE  
- WITH 24 CIRCUIT POWER PANEL
- 11 POWER PEDESTAL  
- 30 AMP, 125 VOLT  
- 50 AMP, 125/250 VOLT
- 11a POWER POLE / POWER HOOK-UP,  
- 200 AMP SERVICE (METER # 189792)
- 12 WATER HOOK-UP PEDESTAL
- 13 WATER HOOK-UP (FOR SNOW MAKING)  
60 PSI, 120 gal/min
- 14 SANITARY HOOK-UP
- 15 LIGHT POLE (REMOVABLE)  
- LIGHT POLE IS TEMPORARY  
- BASE IS PERMANENT  
- POWER SUPPLY IS TEMPORARY
- 16 AREA FLOOD LIGHT  
- CONTROLLED FROM ELECTRICAL BLDG
- 17 PEDESTRIAN CROSS WALK (GRAFTON ST.)

- 18 PERMANENT SITE FENCE
- 18a REMOVABLE FENCE SECTIONS
- 19 TIMBER LANDSCAPED STAIRS
- 20 GENERAL LOCATION OF PORTABLE STAGE
- 21 SCULPTURE
- 22 INFORMATION PANELS
- 23 DATA HOOK UP

GENERAL SITE INFORMATION:

1. PARKING FOR:  
- 253 VEHICLES  
- 5 BARRIER FREE SPACES
2. MAIN ENTRANCE & EXIT ON GRAFTON STREET, SECONDARY ENTRY/EXIT ON WATER STREET.
3. OVERHEAD LIGHTING THROUGHOUT PARKING LOT.
4. WATER, SANITARY AND ELECTRICAL HOOK-UP PEDESTALS ON SITE.
5. CONTOUR IN 0.5m INTERVALS.
6. PDU - POWER DISTRIBUTION UNIT.
7. LP - LIGHT POLE, CONTROLLED FROM ELECTRICAL BUILDING.  
SL - STREET LIGHT, CONTROLLED BY CITY.

3			
2			
1	E.M.	UPDATED SITE INFORMATION	NOV 2014
-	-	-	-
No.	By	Description	Date
REVISIONS			

Consultant



Project Title  
**CHARLOTTETOWN VENUE SITE**  
CHARLOTTETOWN, P.E.I.

Drawing Title  
**VENUE SITE ON-SITE FACILITIES**

Date	NOVEMBER 2014	Designed	Ernie Morello	Bid Pkg No
Checked	E.M.	Scale	N.T.S.	
Drawn	Brian McLellan CET	File Name	Venue Site Information	

This drawing is the property of CADDC and shall not be used on other projects or extensions to this project, or as shop drawings, except in writing from the Architect.

Sheet  
**SP1**  
Rev No. 1